

2022 ANNUAL WATER QUALITY REPORT

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

**West Manchester Township Authority
Shiloh Water System
PWSID NO. 7670101**

The 2022 Annual Water Quality Report is currently in progress and will appear here before March 31, 2023. However there were some sampling violations in 2022 that need to be addressed here before that date. The test for nitrates/nitrites at Wells 1 and 2 should have been taken in the first quarter of 2022 but were missed. Those tests were taken September 21, 2022 and the results were 2.99 and 3.04 ppm respectively, which is well under the limit of 10 ppm as set by DEP. This information will be repeated in the final 2022 Water Quality Report when it is posted here.