

## **West Manchester Township Authority**

### **Facilities Tour**

**July 26, 2021**

**6:30 – 9:30 P.M.**

The West Manchester Township Water Authority conducted its annual facilities tour on July 26, 2021, from 6:30 P.M. to 9:30 P.M. Present at the tour were the following: Jim Bentzel, Chairman, Jake Javitt, Dale Hamme, Gene Williams, W. Lee Woodmansee, John Horvatinovic, and Steve Smith.

The following sites were visited and comments made:

**Office/garage/well#1:** “Mask required” sign was not in place at front door; Exit door in garage was blocked with equipment; miscellaneous equipment/junk was noted in garage; and outside trim of exit door needs to be painted.

**Well #2:** Unnecessary/unneeded items in bldg.; outside door needs to be painted; Gutters need to have gutter guards installed, perhaps with new gutters.

**Well# 3:** Air conditioner in building is unneeded; heater is inoperable and needs to be replaced; exterior of door needs to be re-painted.

**Well #4:** Gutter guards need to be installed.

**Well #5:** No comments.

**Well #6:** Hornet’s nest in vent.

**Wells #7 & 8:** Replace small containment tub with larger one; have miscellaneous pipes on ground sent to salvage yard.

**Well #9:** Poison Ivy, Mulberry Tree(s), and dead tree need to be removed. New outside power shut-off will need a lock when it is completed.

**Deerford Way Tank:** Brush needs to be eliminated around outside of fence.

**Sunset Lane Tank:** No comments.

**Locust Lane Tank:** No comments.